

The Minutes of the online Pre-Bid Meeting (MoM)
Tender for Supply, Installation, Testing and Commissioning of Air-Conditioners (AC) at Savli Technology and Business Incubator (STBI)


Date: 1st September 2021 | **Time:** 02.00 pm


Pre-Bid meeting Webex Link: <https://gog.webex.com/gog/j.php?MTID=mf252f0d1bd96a5ee574c0f0a10c7c861>

The Pre-Bid meeting of the Tender for the Supply, Installation, Testing and Commissioning of Air-Conditioners (AC) at Savli Technology and Business Incubator (STBI) was held virtually at the above referred date and time on Cisco Webex Online Platform. The Pre-Bid meeting was attended by representatives of following companies:

1. Mr. Meshar Khan – Sion Multitech, Vadodara.
 2. Mr. Ashwin Prajapati – Aditi Air Conditioning Pvt. Ltd, Ahmedabab.
 3. Mr. Deepak Solanki – J. D. Lab, Vadodara.
 4. Mr. Shabbir – Aircon Solution, Vadodara.
 5. Mr. Altaf – Sales, Service, Management group, Rajkot
- Mr. Rakeshbhai attended as a representative from Sthapati Architects & Consultants as mPMC for the NIDHI-TBI Infrastructural development at STBI.
 - The following STBI STAFF members also attended the Pre-Bid meeting.
 1. Dr. Anand N Bhadalkar, Director-STBI
 2. Mr. Umang Gondaliya, Manager (Facilities)
 3. Mr. Nirav Patel, Asst. Manager (Prototyping)
 4. Mr. Mayur Joshi, Tech. Asst. (Clean Rooms)
 5. Mr. Mitesh Gandhi, Facility Assistant (Elect.)
 6. Mr. Hitesh Dakhara, Facility Assistant (Mech.)
 - Following query was received and clarified during the meeting:

SN	Chapter/Title/ Sub Title	Page No. in Tender Document	Query/ Clarifications	Response on Query/Clarification
1	BoQ/ Item No - 2/ Stand for ODUs	Page - 35	MS/GI Powder coated stand for ODUs and Steel support structure are considered separately in BOQs. Are these both the items required?	Yes, these both are considered as per requirement.
2	BoQ/ Item No – 2.03.01/drain piping	Page -35	Piping between IDU to ODUs are already considered with an Air-Condition to be supplied from the successful bidder. Is there also any extra piping required?	3m will be considered as integral part of the AC Package. Extra quantity of piping are mentioned in BOQ as per requirement.
3	BoQ/ Item no – 1.01/ Refrigerants	Page – 35	Is any specific requirement for usage of refrigerant?	Yes, allowed refrigerants are mentioned in Item No. 1.01 of BOQ.


Facility Assistant (Elect.),
STBI


Manager (Facilities),
STBI


Director
STBI